



City of Dothan, Alabama

Gravity Grease Interceptor (GGI) 90-Day Cleaning Frequency Waiver Request Form

Date: _____
Facility Name: _____
Facility Address: _____
Contact Name (Printed): _____
Contact Name (Signature): _____
Contact Phone #: _____

Please furnish all monitoring records for a minimum period of 90 days. Include staffing records (Form G) for compliance with the 25% rule and pumping manifests (if applicable). Please note that extending the cleaning (pumping) frequency beyond a 90-day period will result in progressively lower pH in the GGI and accelerated corrosion of the interceptor. The waiver request will not be considered without sufficient documentation.

Mail to:

City of Dothan
Attn: FOG Program
P.O. Box 2128
Dothan, Alabama 36302

Or Email to:

strawick@dothan.org

Or FAX to:

Dothan Utilities (Admin Office)
(334) 615-3309

For City of Dothan FOG Program use only

() **Denied** - After careful review of the FSE gravity grease interceptor (GGI) monitoring and clean out (pump) frequency records, including the “FSE Gravity Grease Interceptor Self-Monitoring Checklist (Form G)” for compliance with the 25% rule, a waiver requiring a clean out of the interceptor on a minimum 90-day schedule is hereby denied.

Reason for Denial

- () Insufficient record keeping or monitoring frequency.
- () Records indicate that the GGI exceeds the 25% rule.
- () Staffing conducted for compliance with the 25% rule by the FOG Program indicates > 25% FOG + food solids.

() **Granted** - After careful review of the FSE gravity grease interceptor monitoring and clean out (pump) frequency records, including the “FSE Gravity Grease Interceptor Inspection Self-Monitoring Checklist (Form G)” for compliance with the 25% rule, a waiver requiring a clean out of the interceptor on a minimum 90-day schedule is hereby granted. The interceptor shall be pumped-in-full (total pump of all contents) when the total accumulations of FOG (fats, oils, and grease), including floating solids, and settled solids reaches twenty-five percent (25%) of the grease interceptor’s overall liquid depth. The FSE is to continue to monitor/inspect the interceptor frequently enough to ensure compliance with the aforementioned 25% rule, as well as maintain each “FSE Gravity Grease Interceptor Self-Monitoring Checklist (Form G)” and “Non-Hazardous Waste Manifest” onsite. These records shall be kept for a minimum of three (3) years and be available for inspection. The City retains the right to require an increased pumping and monitoring frequency for interceptors found to be overloaded and not pumped or for failure of the FSE to provide detailed records.

FOG Program Supervisor